



Energy Efficiency opportunities in the Agri-Food Sector: a success case in using efficient refrigeration systems

Matteo Locati





Agenda



Energy Efficiency opportunities in the Agri-Food Sector: a success case in using efficient refrigeration systems

- Plant Energy Analysis
 - Context
 - Results
- Technical-economic feasibility study
- Energy saving intervention implementation
- Other Energy Saving intervention






Project road map



Integrated approach towards Energy Efficiency








Structured analysis of the energy consumption of the plant aimed at:













Electric energy seasonal load profile (winter)

Electric energy seasonal load profile (summer)










Electric consumption classification by technological area

Overall consumption classification by technological area





Feasibility study



Intervention:

 Replacement of the existing chiller with a new high-efficiency machine

Quantification of the correct cooling needs

Evaluation of different technological alternatives

Choice of the new machine through economic indicators






Feasibility study



CHILLER	Circuits	kWc	kWe *	EER
30 GX 247 (EXISTING)	2	809	297,0	2,72
30 RB 0802 - MULTISCROLL	3	768,8	300,7	2,56
30 XAV 0800 - SCREW INVERTER	2	813,1	242,5	3,35

Technological alternatives






^{*} Standard Eurovent Conditions: Evaporator entering/leaving water temperature 12°C and 7°C. Outdoor air temperature 35°C



Feasibility study




Economic Indicator	Value		
Pay-Back Time (PBT)	3,2		
Net Present Value (NPV)	255.000 €		
Internal Rate of Return (IRR)	33,8%		





Measuring and quantification











Intervention proposals

Intervention	Priority	Intervention classification	Good practice EU MERCI
Replacement of the current chiller with a high-efficiency unit	High	Technological	Yes
Installation of speed-regulation systems according to effective load on pumps for chilled water	High	Technological	Yes
Enlarge the tolerance of temperature and humidity set-points to avoid continuous heating/cooling and humidifying/drying in cells	High	Procedural	
Specific maintenance activities on air treatment centres	High	Procedural	
Introduction of maintenance and equipment/machinery purchase policies, focusing on energy consumption drivers and costs on plant lifecycle	High	Procedural	
Installation of a VSD machine for compressed air production	Medium	Technological	Yes
Intervention on batteries of condensers of the current re-phasing system (the value of the power factor is below 0,9 in all months)	Medium	Technological	
Installation of a plant for pre-cooling in summer and pre-heating in winter for external air of all air treatment centers	Medium	Technological	Yes
Replacement of current fluorescent T8 tube bulbs having a ferromagnetic power unit with LED lamps	Medium	Technological	
Replacement of heaters burners (now using agricultural diesel) with new biomass burners	Medium	Technological	Yes
Installation of a natural gas trigeneration plant	Medium	Technological	Yes
Installation of a high-pressure humidification plant	Low	Technological	




Other interventions



Compressed air production:

- 1. Leaks detection and reduction
- 2. Reduction of circuit pressure
- 3. Substitution of a load/unload machine with a VSD machine

Specific Consumption (SC – kWh/Nm3) before and after interventions






Other interventions



Trigeneration plant:

Feasibility study through simulation of future consumptions in





Perspectives







ISO 50001 Certification



Energy Management System (EMS)

Energy Analysis and interventions



